CERTIFICATE

KBTLtd

132 Saltley Road Saltley

Birmingham

B7 4TH



Certificate No.	5453
Order No.	

Date 18/05/11
Fabric Black
Length 0.25 metres

This is to certify that we have carried out an in-house test on a sample of the supplied fabric detailed above.

The results from the test show a satisfactory PASS to BS 5867 : Part 2 : Type B. 2008 (Tested according to EN-ISO 15025: 2002 Face Ignition).

No tests have been carried out on the durability of the fabric's flame retardant properties, and we are therefore unable to provide any recommendations regarding fabric care.

Yours faithfully

For J E Talbot B.Sc (Head of Testing) GS/F/12

